



SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (A) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (B) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (C) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (D) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (E) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (F) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (G) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (H) S2

SECTION SCALE $\frac{3}{4}'' = 1'-0''$ (I) S2

SECTION SCALE $\frac{1}{2}'' = 1'-0''$ (J) S2

SECTION SCALE $\frac{1}{2}'' = 1'-0''$ (K) S2

FIRST FLOOR PLAN SCALE $\frac{1}{8}'' = 1'-0''$

WHEREVER CORNERS OF COLUMNS AND ELEVATOR WALLS ABUTT CONC. SLAB ON GRADE ADD ONE #4 @ 2'-0" DIAGONALLY @ EACH CORNER TYP. AS SHOWN. DIAGONAL STL. MUST NOT PASS THRU OR INTERRUPT C.J.T'S

4" CONC. SLAB ON GRADE W/ ONE LAYER 6x6 10x10 W/WF 4 G MIL PLASTIC VAPOR BARRIER

TYP. KEYED-KOLD JOINT

FIN. FLOOR ELEV. 14'-0" 4" CONC. SLAB

NOTE: WHEREVER CONC. SLABS ON GRADE ABUTT VERTICAL CONC. OR MASONRY SURFACES THEY SHALL BE SEPARATED BY A 1/8" ISOLATION JOINT (I.J.) (NEOPRENE OR ASPHALT FELT)

KEYED-KOLD JOINT