



SEE SHEET NO E-1 FOR WALKWAY LIGHTING

SEE SHEET NO B-1 FOR CANOPY LIGHTING

SEE SHEET NO E-1 FOR WALKWAY LIGHTING

APARTMENT PANELBOARD PB-B SCHEDULE						APARTMENT PANELBOARD PB-C SCHEDULE					
ITE EQ20A, 120/208, 2P-3W, SN. 150A M.L.O., 20-IP SPACES, FLUSH MT.						ITE EQ14, 120/208, 2P-3W, SN. 125A M.L.O., 16-IP SPACES, FLUSH MT.					
CIRCUIT	VOLTS	POLES	BKR	WIRE	PURPOSE	CIRCUIT	VOLTS	POLES	BKR	WIRE	PURPOSE
C-1	208V	2	60A	2#0 THHN #2 TV	12 KW RANGE	C-1	120V	2	40A	2#8, 1#10	8.3 KW RANGE
C-2	DO	2	30A	#10	3 KW WATER HEATER	C-2	120V	2	30A	#10	3 KW WATER HEATER
C-3	DO	2	SEE WIRING TABLE		ELECTRIC HEATER	C-3	120V	2	SEE WIRING TABLE		ELECTRIC HEATER
C-4	DO	2	SEE WIRING TABLE		AC UNIT	C-4	208V	2	SEE WIRING TABLE		AC UNIT
C-5	120V	1	15A	#12	AH UNIT	C-5	120V	1	15A	#12	AH UNIT
C-6	DO	1	20A	#12	DISPOSAL	C-6	120V	1	20A	#12	APPLIANCE
C-7	DO	1	20A	#12	DISHWASHER	C-7	120V	1	20A	#12	DO
C-8	DO	1	20A	#12	APPLIANCE	C-8	120V	1	20A	#12	LIGHTING
C-9	DO	1	20A	#12	DO	C-9	120V	1	20A	#12	DO
C-10	DO	1	20A	#12	DO						
C-11	DO	1	20A	#12	LIGHTING						
C-12	DO	1	20A	#12	DO						
C-13	DO	1	20A	#12	DO						

NOTES:  
 1. ALL CONDUCTORS TO BE COPPER. ALUMINUM IS NOT ACCEPTABLE  
 2. NO MORE THAN 2 CONDUCTORS TO BE RUN IN A SINGLE CONDUIT, WITHOUT INCREASING WIRE SIZE TO OFFSET DERATING FACTOR.

WASHER + DRYER BREAKERS-  
 PANELS ON 1ST + 3RD FLOOR  
 PB-F  
 PB-H LAUNDRY ROOMS  
 NOT SHOWN ON PLANS  
 H.S.H.

PARTIAL GROUND FLOOR ELECTRICAL PLAN  
 SCALE 1/4" = 1'-0"

THE RIVERSIDE FOR EIGHT MANAGERS CORP. ROBERT L. SHAW, AIA