



- LEGEND:**
- SW — STEAM WATER PIPING
  - S.W. — SANITARY WASTE OR SOIL PIPING
  - S.V. — SANITARY VENT PIPING
  - C — CLEANOUT
  - T — TEST TEE CLEANOUT
  - F — FLOOR DRAIN
  - DW — DOM. COLD WATER PIPING
  - HW — DOM. HOT WATER PIPING
  - COE — FIRE EXTINGUISHER (CO<sub>2</sub>)
  - DC — FIRE EXTINGUISHER (DRY CHEMICAL)
  - CD — A/C CONDENSATE DRAIN PIPING

- GENERAL NOTES:**
1. THE PLUMBING SUB CONTRACTOR SHALL VERIFY THE LOCATION OF ALL EXISTING SERVICES AS TO SIZE, INV. LEVEL & LOCATION (WATER, SANITARY SEWER, ETC.)
  2. THE PLUMBING CONTRACTOR SHALL CO-ORDINATE HIS WORK WITH ALL OTHER TRADES & CONTRACTORS.
  3. ALL SANITARY PIPING BELOW FINISH FLOOR SHALL BE INSTALLED ON EXTRA HEAVY VITRIFIED CLAY PIPE.

PUMP NUMBER	PUMP SCHEDULE	
	1	2
SERVICE	DOM. WATER	FIRE
MANUFACTURER	AUGER	ALLIS CHALMERS
MODEL NUMBER	2X2 1/2 X 17 1/2	2X10 1/2 X 5 1/2
FLOW CAPACITY	GPM 120	250
TOTAL DYNAMIC H2O	FT 80	100
IMPELLER DIAMETER	IN 12	5 1/2
PUMP MOTOR SPEED	RPM 1750	1750
PUMP MOTOR HP	HP 5	10
PUMP MOTOR ELEC. SIC DATA	220V. 3Ø 900	220V. 3Ø 900
TYPE OF MOTOR	MECHANICAL	MECHANICAL
TYPE OF SHAFT SEAL	MECHANICAL	MECHANICAL
PUMP SECTION & DISCHARGE	2" X 2 1/2"	2" X 2 1/2"
CONC. BASE SIZE	24" X 24" X 4"	24" X 24" X 4"

ROBERT L. SHAW, AIA  
 THE RIVERSIDE FOR FIRST WATERS CORP.  
 ARCHITECT, INC.  
 1001 N. W. 10TH AVENUE, SUITE 100  
 MIAMI, FLORIDA 33136